



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 5/11/09

Code 60-09

#### INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E3501		Page 653
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>(1) Delete the definition of APPROVED and substitute to read as follows: See the definition of APPROVED in Section <b>R202</b>.</p> <p>(2) After the definition of BRANCH CIRCUIT, MULTIWIRED, add the definition of BRANCH-CIRCUIT OVERCURRENT DEVICE to read as follows: A device capable of providing protection for service, feeder, and branch circuits and equipment over the full range of overcurrents between its rated current and its interrupting rating. Branch-circuit overcurrent protective devices are provided with interrupting ratings appropriate for the intended use but no less than 5,000 amperes.</p> <p>(3) After the definition of CIRCUIT BREAKER, add the definition of CLOTHES CLOSET to read as follows: A non-habitable room or space intended primarily for storage of garments and apparel.</p> <p>(4) After the definition of FITTING, add the definition of GARAGE to read as follows: A building or portion of a building in which one or more self-propelled vehicles can be kept for use, sale, storage, rental, repair, exhibition, or demonstration purposes.</p> <p>(5) Change the definition of Grounding Electrode Conductor to read as follows: A conductor used to connect the grounding electrode(s) system grounded conductor or the equipment to the equipment a grounding conductor electrode or to a point on the grounded conductor, or to both, at the service equipment, at each building or structure where supplied by a feeder(s) or branch circuit(s), or at the source of a separately derived grounding electrode system.</p> <p>(6) After the definition of IDENTIFIED, add the definition of IN SIGHT FROM (WITHIN SIGHT FROM, WITHIN SIGHT) to read as follows: Where this code specifies that one equipment shall be "in sight from", "within sight from", or "within sight of", and so forth, another equipment, the specified equipment is to be visible and not more than 50 feet distant from the other.</p> <p>(7) Delete the definition of LABELED and substitute as follows: See the definition of LABELED in Section <b>R202</b>.</p> <p>(8) Delete the definition of LISTED and substitute to read as follows: See the definition of LISTED AND LISTING in Section <b>R202</b>.</p> <p>(9) In the definition of LOCATION, WET, before "locations exposed to weather", insert ", in unprotected".</p> <p>(10) After the definition of SERVICE POINT, add the definition of SHORT-CIRCUIT CURRENT RATING to read as follows: The prospective symmetrical fault current at a nominal voltage to which an apparatus or system is able to be connected without sustaining damage exceeding defined acceptance criteria.</p>		
REASON AND FISCAL IMPACT		
This text was extracted from the 2005 Indiana Residential Code.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		